


 Customer Name: **Goring Church**

Site Address:

Postcode:

Site Reference Number:

M 4203

Customer Order Number:

S1A

 Equipment: Fire Alarm ☒

 Disabled Refuge ☐

Other:

Applicable to BAFE SP203-1 Maintenance Certification:

BAFE Reg. No. 101799

False Alarm Details:

Cause of False Alarm

Equipment fault

Unwanted

Transmission Fault

Malicious

Good Intent

Cause not Known

Did Brigade Attend:

Yes

No

No. of false alarms since last Service visit *

0

No. of false alarms over last 12 months

No. of false alarms per 100 automatic fire detectors per annum

Is further action required?

Yes

No

☒

Power Supplies Checked *

☒

Charge volts:

13.2

Volts

Standby battery load tested #

☒

Standby Period:

-

Hrs

Battery volts:

13.0

Volts

Battery size fitted:

1x13v34 AH

Quiescent load:

-

Amps

Alarm load:

-

Amps

Description of Work Carried Out / Engineer's Report:

CARRIED OUT A 50% SERVICE OF THE FIRE ALARM SYSTEM. SEE TEST SCHEDULES FOR DEVICES TESTED AT THIS VISIT. NO FAULTS FOUND. SYSTEM LEFT IN WORKING CONDITION.

Variations from the recommendations of clause 45 of BS 5839-1 for periodic or annual inspection and test (for Fire Alarm Maintenance visits only):

Materials Used:

QTY	Make	Model	Description	QTY	Make	Model	Description

Labour:

Engineer's Name	Arrive	Depart	Travel Time	Total Hours
			+	
			+	

We, being currently a BSI Certified Company in respect of Fire Detection and Alarm Systems of the type(s) we have identified above (only applicable if completed) certify that the maintenance work detailed above complies with the Standard and / or Code of Practice identified and with all other requirements of the BAFE SP203-1 Scheme in respect of such a system.

 YES ☐

 NO ☐

 N/A ☐

Where applicable to the work carried out above, I/We being the competent person(s) responsible for the servicing of the system(s) described above certify that the work complies to the best of my/our knowledge and belief with the recommendations of clause 45 of BS 5839-1 for periodic inspection and test/inspection and test over a 12 month period, except for the variations if any stated in this certificate. For and on behalf of Crays Fire:

Engineer's Sig:

Print:

DANNY HINSWICKWOOD

Date:

09.09.2025

I have denied permission for the alarm sounders / outputs to be tested as required by the above standard:

 YES ☐

 NO ☐

 N/A ☐

I confirm that the above works have been carried out to my satisfaction and accept responsibility for the system including defects that have been brought to my attention as or on behalf of the nominated Responsible Person:

Customer's Sig:

E Swierk

Print:

E SWIERK

Date:

9.9.25